



TYP. FLOOR PLAN WITH/
WITHOUT PIPE RISER
(DROP INLET FOR TYPE "C" & "D")

- ## NOTES:
1. FOR REINFORCING STEEL AND CONCRETE QUANTITIES SEE STD DWG CB 6H
 2. PLACE 5-A1 AND 5-B3 BARS AT 3" SPACING FROM OPENING IN TOP SLAB OF EACH BOX. SPACE ALL ADDITIONAL BARS, WHERE REQUIRED, AT 12" MAX. O.C. IN TABLE #5 ONLY 1-B3 BAR IS REQUIRED FOR EACH BOX. SPACE ALL OTHER BARS AS PREVIOUSLY DESCRIBED.
 3. PLACE IN FLOOR OF BOX AROUND THE PERIPHERY OF EACH CMP RISER. STANDARD ANCHOR BOLTS $3\frac{3}{4}" \times 6"$ ON 24 INCH CENTERS. POSITION ANCHOR BOLTS 3" FROM END OF RISER. ANCHOR BOLTS AND NUTS: CONFORM TO ASTM SPECIFICATION A 307 AND A 563, GRADE C, RESPECTIVELY. INCLUDE PAYMENT FOR FURNISHING AND PLACING ANCHOR BOLTS AND NUTS IN THE PRICE PER LINEAR FOOT OF PIPE.

[illegible]